

**Failure to fully complete this form may result in rejection.
Making a false statement may result in a fine or prosecution
under the *Technical Standards and Safety Act***

Licence Number

Check applicable type of propane operations.

Cylinder Motor Fill Filling Plant Card/Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.

For Office Use Only

SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

A	Company Name U-Haul Co. (Canada) Ltd	Ontario Corporation No., if applicable
	Operator Name (if different from above)	
	Telephone No. 905-578-9119	Fax No.
	E-mail jackie_romyn@uhaul.com	

B	Street No. 2890	Street Name / 911 Number / Address, if applicable Dougall Ave.
	Town / City or Township / County Windsor	Province Ontario
	Postal Code N9E1R9	

Mailing address if different from above.

C	Street No. 2275	Street Name / 911 Number / Address, if applicable Barton St.
	Town / City or Township / County Hamilton	Province Ontario
	Postal Code L8E2W8	

Information on Container Refill Centre or Filling Plant

D	Street No. 2890	Street Name / 911 Number / Address, if applicable Dougall Ave.	Nearest Major Intersection Dougall @ EC Row Parkway
	Town / City or Township / County Hamilton	Province Ontario	Postal Code N9E1R9

Name of Licence Holder U-Haul Co. (Canada) Ltd	
Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT). John Fisher	ROT type 100-01 (Propane Pump Attendant)
Municipality (or municipalities if the facility or its hazard distance touches multiple borders) Essex	
Hours of operation. <div style="background-color: black; width: 100%; height: 50px;"></div>	



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)


Indicate the year the facility was established. 1987	Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment. N/A
---	--

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	250 PSIG	7270
Tank 2:		
Tank 3:		

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 2000 USWG Portable: 0 USWG Mobile: 0 USWG





Technical Standards and Safety Authority
www.issa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Activity Information

Name of Propane Supplier(s) Superior Propane- Ontario Regional Operations Centre		Fr [REDACTED]	
Street No. 251	Street Name / 911 Number / Address, if applicable Woodlawn Road West Unit 217		
Town / City or Township / Country Guelph		Province Ontario	Postal Code N1H 8J1
Telephone No. 1-877-873-7467	Fax No. 519-836-7766	Contact Name Mike Mullins	
E-mail mullinsm@superiorpropane.com			

Name of Propane Transporter. If same as above, please check box. <input type="checkbox"/>		Fr [REDACTED]	
Superior Propane - Guelph Bulk Propane Yard			
Street No. 7022	Street Name / 911 Number / Address, if applicable Wellington Road 124		
Town / City or Township / Country Guelph		Province Ontario	Postal Code N1H 6L3
Telephone No. 1-877-873-7467	Fax No. N/A	Contact Name Jason Swan	
E-mail swanj@superiorpropane.com			

Off-site Cylinder and/or Mobile Storage N/A	Capacity stored off-site, in USWG N/A	For Office Use - Party No.	
Street No.	Street Name / 911 Number / Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant		
Signature 	Telephone No. 905-578-9119	Date (dd-mm-yyyy) 06/12/2011	



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

N/A

Description of fire and emergency equipment indicated on facility site map.

Fire Extinguishers


List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

Fusible Link on the ISC Valve, Manual Shutoff (Remote E-Stop button in office)

Maintenance and testing schedule for fire protection controls and devices.

Maintenance and Testing will be undertaken by Superior Propane according to it's Maintenance Standard. FX maintenance to be done by qualified/trained personal as per NFPA 10 - annually, monthly FX inspections required as per Ontario fire code.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant	
Signature 	Telephone No. 905-578-9119	Date (dd-mm-yyyy) 06/12/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact		5. Facility 24-Hour Contact Person	
Name Josh Ruckle	For Office Use - Party No.	Name Josh Ruckle	For Office Use - Party No.
Official Title General Manager		Official Title General Manager	
Telephone No. (519) 966-3880	Fax No. N/A	Cell No. 519-999-5674	Fax No. N/A
E-mail josh_ruckle@uhaul.com		E-mail josh_ruckle@uhaul.com	
Role and responsibilities in emergency Incident Commander		Role and responsibilities in emergency Incident Commander	
2. Facility Contact Personnel - Alternate Contact		6. Name of Facility Manager	
Name Nick Marucio	For Office Use - Party No.	Name Josh Ruckle	For Office Use - Party No.
Official Title Customer service rep.		Official Title General Manager	
Telephone No.	Fax No. N/A	Telephone No. (519) 966-3880	Fax No. N/A
E-mail		E-mail josh_ruckle@uhaul.com	
Role and responsibilities in emergency Alternate incident commander		Role and responsibilities in emergency Incident Commander	
3. Local Fire Services - Key Contact		7. Propane Supplier Key Contact Person	
Name Steve Laforet	For Office Use - Party No.	Name Superior Propane HotLine	For Office Use - Party No.
Official Title Deputy Chief		Official Title	
Telephone No. 519-253-3016 x253	Fax No. 519-255-6832	Telephone No. 1-877-873-7467	Fax No.
E-mail slaforet@city.windsor.on.ca		E-mail	
Role and responsibilities in emergency Co-ordinate fire department response		Role and responsibilities in emergency Supplier Contact	
4. Local Fire Services - Alternate Contact		8. Municipal Contact	
Name Brian McLaughlin	For Office Use - Party No.	Name Valerie Critchley	Party No.
Official Title Deputy Chief		Official Title City Clerk/ Licence Commissioner	
Telephone No. 519-253-3016 x 272	Fax No. 519-255-6832	Telephone No. 519-255-6222 x 6434	Fax No. 519-255-6832
E-mail bmclaughlin@city.windsor.on.ca		E-mail vcritchley@windsor.on.ca	
Role and responsibilities in emergency Co-ordinate fire department response		Municipality Windsor	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant
Signature 	Telephone No. 905-578-9119
	Date (dd-mm-yyyy) 06/12/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.
See attached emergency plan document.

[Large empty lined area for describing additional safety measures]

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant	Date (dd-mm-yyyy) 06/12/2011
Signature 	Telephone No. 905-578-9119	



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy) 17-06-2010	Print Name of Training Provider: U-Haul Co. Canada Ltd.
	Print Name of Instructor: Brian Leech
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy) 18-06-2010	Print Name of Training Provider: U-Haul Co. Canada Ltd.
	Print Name of Instructor: April Chappus
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy) 18-06-2010	Print Name of Training Provider: U-Haul Co. Canada Ltd.
	Print Name of Instructor: April Chappus
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant
Signature 	Telephone No. 905-578-9119
	Date (dd-mm-yyyy) 06/12/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) 15-10-2011	Print Name of Training Provider: U-Haul Co. (Canada) Ltd
	Print Name of Instructor: Brian Leech
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy) 15-10-2011	Print Name of Training Provider: U-Haul Co. (Canada) Ltd
	Print Name of Instructor: Josh Ruckle
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy) 15-10-2011	Print Name of Training Provider: U-Haul Co. (Canada) Ltd
	Print Name of Instructor: Josh Ruckle
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant
Signature 	Telephone No. 905-578-9119
	Date (dd-mm-yyyy) 06/12/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).
Incident Commander / Floor Warden will contact local fire authorities immediately.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

Floor Warden direct all staff and vistors to leave the building via the safest route, inspect area that all staff and visitors have evacuated. Ensure that all employees and visitors have assembled in the safe area at the KFC parking lot at the corner of Dougall/W. Grand. Floor warden will report the status of there section to the Incident Commander. The Incident Commander will advise the Fire Dept. of any individuals remaining in the location.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

Incident commander will give verbal warning to all present and place a call to 911.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

Site is open and no obstructions to Propane Facility. Pad lock on propane dispensing section.

Describe how the licence holder will ensure continual flow of updated information to authorities.

The Incident Commander will Liaise with the Fire Department to provide any assistance that they require and ensure that the emergency operation centre is staffed.

How long will it take the facility liaison person to respond to the site.

15 minutes

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant	Date (dd-mm-yyyy) 06/12/2011
Signature 	Telephone No. 905-578-9119	



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Is there adequate night lighting at the site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6. Are weighing systems validated for accuracy?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9. Is the schedule of maintenance and testing activities retained on site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	25m	
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)	N/A	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant	
Signature 	Telephone No. 905-578-9119	Date (dd-mm-yyyy) 06/12/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes

No

If not, please explain (e.g., no fire services).

Fire services comments, if any:

See notes contained within Appendix A.

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

All corrections made as per Windsor fire.

The licence holder will respond to the Local Fire Services comments by: 01/01/12

(dd-mm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Local Fire Services Name	Print name	Signature	Date (dd-mm-yyyy)
WIFRS	Andrea De Jong		25/01/2012

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant
Signature 	Telephone No. 905-578-9119
	Date (dd-mm-yyyy) 06/12/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy) 15-02-1997	Capacity of single largest propane storage vessel (USWG) 2000 USWG
Tank setback coordinates. Indicate placement on the map.	
Front: 10m _____	Right side property line: 45m _____
Rear: 40m _____	Left side property line: 10m _____
GPS coordinates of single largest vessel: 42.275181, -83.014938 _____	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant
Signature 	Telephone No. 905-578-9119
	Date (dd-mm-yyyy) 02/12/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)
Applicant must include a Facility Site Plan and Map of Surrounding Area


Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
 D = Distance to overpressure of 1 psi (meters)
 C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
 Assume all vessels are 80% full
 1 gallon [US, liquid] = 0.003785411784 cubic meter
 1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romy	Official Title Executive Assistant
Signature 	Telephone No. 905-578-9119
	Date (dd-mm-yyyy) 06/12/2011



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				_____ m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				_____ m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: Commercial plaza Address: 2950 Dougall Avenue City: Windsor Province Ontario Postal Code N9E 1S2			X		45 m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				_____ m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				_____ m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____	X				_____ m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant	Date (dd-mm-yyyy) 06/12/2011
Signature 	Telephone No. 905-578-9119	



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

**Level 1 Risk and Safety Management Plan (RSMP);
Technical Standards and Safety Ac.
Propane Storage and Handling Regulator**

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

Portable Storage Additional Information Sheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9	N/A	
# 100	29.5	N/A	
# 40	11.75	N/A	
# 33.3	9.62	N/A	
# 30	8.8	N/A	
# 20	5.8	N/A	
# 10	2.9	N/A	
# 5	1.5	N/A	
Total Cylinder Capacity N/A			

Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantity	Total Volume in USWG
#20	< 10	Empty
Total Tank Capacity N/A		

Total Cylinder Capacity	N/A
Total Tank Capacity	N/A
Total Portable Capacity	N/A


Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Jackie Romyn	Official Title Executive Assistant	Date (dd/mm/yyyy) 06/12/2011
Signature 	Telephone No. 905-578-9119	

Dougall Drive

EC Row (East, West bound)

W. Grand Ct.



Location: 2890 Dougall Drive Windsor, Ontario N9E 1R9
Prepared: January. 20, 2012

Property line

2000 USG Vertical tank

Tank setbacks: front 10m, rear 40m, right 45m, left 10m

Radius = 246m

GPS coordinates: 42.275181, - 83.014938

Municipality: City of Windsor

City clerk: Valerie Critchley





Address: 350 City Hall Square West Windsor, Ontario N9A 6S1

**PROPANE BRANCH STANDARD
NUMBER 9 STATISTICS**

AREA A = 0 sq. ft.
 AREA B = 0 sq. ft.
 AREA C = 8198.5 sq. ft.
 AREA D = 10,830.0 sq. ft.
 AREA E = A + (B x 2) = 0 sq. ft.
 AREA F = C + (D x 2) = 29,858.5 sq. ft.

A/G TANK

AREA E + (AREA F x 0.1)
 = 0.0 + (29,858.5 x 0.1)
 = 2985.9 sq. ft.



- NOTES:**
1. AREAS SHOWN REPRESENT PORTIONS OF BUILDINGS DIMENSIONED BY THE 0-75 FEET AND 75-300 FEET RADIUS AS INDICATED.
 2. AREAS CALCULATED ARE USED FOR VEHICULAR PROPANE BRANCH STANDARD #9 REQUIREMENTS.
 3. AREA REQUIREMENTS FOR BRANCH STANDARD #9 IS 2985.9 SQ. FT. WHICH IS LESS THAN THE 15,000 SQ. FT. ABSTRACTION FACTOR IS IN COMPLIANCE WITH BRANCH STANDARD #9.
 4. SITE IS IN COMPLIANCE WITH CAN/CSA-149.2-1993 CODE REQUIREMENTS, AS PER APPROVED DISTANCES IF LOCATED AS SHOWN. ALL EQUIPMENT IS TO MEET APPLICABLE CODE REQUIREMENTS.
 5. ANY UPPER STOREYS OF BUILDINGS THAT FALL WITHIN THE 15 FEET AND 300 FEET RADIUS ARE ALSO USED IN CALCULATING BRANCH STANDARD #9 LIMITS.
 6. INTERFERENCE INDEX FROM INTERFERENCE PROVIDED BY ICC PROPANE INC. AND A SITE VISIT BY ALIENIC PERSONNEL CONDUCTED ON FEBRUARY 2, 1999.
 7. ALL MECHANICAL AND ELECTRICAL EQUIPMENT TO BE APPROVED FOR PROPANE USE AND INSTALLED IN THE APPROPRIATE CLASSIFIED AREAS (i.e., HAZARDOUS, NON-HAZARDOUS, ETC.).
 8. ELECTRICAL CABLES TO BE BROUGHT TO TANK BY U-HAUL.
 9. ELECTRICAL EQUIPMENT MUST BE CLASS 1, GROUP 0, DIVISION 2 IF WITHIN 4.5 M (15 FT.).
 10. FACILITY USED FOR CRUISE FILLING AND ALSO PROPANE DISPENSING.
 11. PROPANE DISPENSING DEVICES TO BE AT LEAST 3 M (10 FT.) FROM DRAINAGE BASIN OR BENCH CLAUSE 10.28(6) OF PROPANE INSTALLATION CODE.
 12. DISTANCES OF TANK AND DISPENSER FROM EACH BASIN TO BE MINIMUM 6.52 M (21 FT.) AS PER CAN/CSA-149.2-1993 CODE. INSTALLER TO VERIFY SITE CONDITIONS ARE IN COMPLIANCE.
 13. OCCUPANCY CLASSIFICATIONS HAVE BEEN SELECTED BY "MARK OCCUPANCY" AS DEFINED BY THE ONTARIO BUILDING CODE 1990, WHERE DUAL OCCUPANCY CLASSIFICATIONS EXIST, THE MAIN FUNCTION HAS BEEN PRESUMED. (i.e., MERCHANTILE JOY RIDING, ETC., IF CLASSIFICATION USED) UNLESS OTHERWISE SHOWN.
 14. TANK DIMENSIONS ARE TYPICAL, ACTUAL TANK DIMENSIONS MAY VARY.
 15. ONTARIO PROPANE CODE 1996, AMENDMENT # 14 REQUIRES FURTHER PROTECTION TO FEEL (3.05) METERS FROM TANK SURFACE IF DISPENSER IS LOCATED TO FEEL (3.05) METERS OR CLOSER TO THE TANK. IF DISPENSER IS LOCATED MORE THAN 10 FEET (3.05) METERS FROM THE TANK, DISPS CAN BE LOCATED 3 FEET (1.0) METERS FROM TANK.
 16. SITES COMPLYING WITH CLAUSE 10.12 OF THE CAN/CSA-149.2-1993 SHALL BE PROHIBITORYLY DISPLAYED.
 17. FOUNDATION SHOWN IS BASED ON ACCEPTING TANK AND SINK ASSEMBLY AS CONSTRUCTED BY ICC PROPANE INC. ACTUAL AND DIMENSIONS MAY VARY, HOWEVER IT MUST MEET ACCEPTANCE OF CAN/CSA-149.2-1993 CLAUSE 10.11 AND APPROVAL OF AUTHORITY HAVING JURISDICTION.
 18. NOTE: NEER CODE STATES THE INSTALLATION MUST ACCOMMODATE AN EMERGENCY SHUT-OFF SWITCH FOR THE PROPANE AND POWER. SECTION 10.15.1.7 AND 10.1.6 OF CAN/CSA-149.2-1993 SHOULD BE REVIEWED BEFORE STARTING CONSTRUCTION.
 19. DRAWING FOR VEHICULAR APPROVAL ONLY.

A 324/24/1.C.C. Equipment Orientation Change
 Rev. 1.0 Date: 11/01/2011 By: [Signature]

U-HAUL UNIT #839-59
ICG ICG PROPANE INC.
ALTENG ENGINEERING

126 Main Cres., Thornhill, Ont. L3T 5J3 (905)761-1644

Plot No.	Plot Name	Plot Area	Plot Date
PL01	N/A	971680	02/08/97

Scale: 1" = 400'

Client: U-HAUL CENTRE WINDSOR
 2890 Dougall Drive
 Windsor, Ontario N9E 1R9

Project No: 971000

Date: PROPOSED 2000 USING VERT. TANK c/w CYL. & AUTO (RS)?